

# LANSDALE

## VALVE & MANUFACTURING

1040 Broadway Westville, NJ 08093 / Phone: (800) 908-0523 / Fax: (856) 456-9223 / [www.gemfiresprinkler.com](http://www.gemfiresprinkler.com)

## FIRE DEPARTMENT CONNECTION PLASTIC BREAKABLE CAPS

**2½" 350-125-01780**

### DESCRIPTION:

Plastic Breakable caps provide protection against the introduction foreign material into the swivels but allow for quick access when a hose connection is necessary.

The Plastic Breakable Caps for Fire department Connections are injection molded polystyrene. Each set includes two caps and 4 eyelets with nuts for 2½" swivels. The caps have been molded with "scored" tabs for easy removal with a hydrant wrench or other similar tool.

### INSTALLATION:

Remove the caps from their packaging. Hold the breakable cap to the opening of swivel. Align the breakable tabs with the pin lugs on the swivel. Insert the threaded end of one eyelet through the hole in the tab of the cap then Once aligned, slide the eyelet over the pin lug. Once the eyelet is in place, carefully thread the included 1/4 -20 finished hex nut onto the threaded end of the eyelet until snug.

**Material:** Injection Molded Polystyrene

**Size:** 2½" swivel

**Type:** Pin lug

**Included per set:** (2) caps, (4) eyelets, (4) hex nuts

**\*Available in sets only**



**Caution:** Do not over tighten. The tabs of the break caps are designed to break with minimal force.

PROJECT	APPROVAL STAMP
PROJECT:	<input type="checkbox"/> APPROVED
ADDRESS:	<input type="checkbox"/> APPROVED AS NOTED
ENGINEER:	<input type="checkbox"/> NOT APPROVED
SUBMITTAL DATA:	REMARKS:
NOTES 1:	
NOTES 2:	

**Revision: 1/2019**