


1040 Broadway Westville, NJ 08093 / Phone: (800) 908-0523 / Fax: (856) 456-9223 / www.gemfiresprinkler.com

HINGED SPLIT RING





| MATERIAL | Malleable Iron | | |
|-------------------|--|---------------------------------------|--|
| MATERIAL STANDARD | ASTM A47 Grade 32510 | | |
| SURFACE FINISH | 508P# & 508RP# 508Z# & 508RZ# 508RC# | Plain Zinc Plated Copper Plated | |

| Pipe | Pipe | Bolt | Н | | Max. Rec |
|--------|--------|--------|------------|----------|-----------|
| Size | Thread | Thread | Plain/Zinc | Cooper | Load/lbs. |
| 3/8" | 1/4" | 3/8" | 21/32" | 21/32" | 180 |
| 1/2" | 1/4" | 3/8" | 3/4" | 3/4" | 180 |
| 3/4" | 1/4" | 3/8" | 27/32" | 27/32" | 180 |
| 1" | 1/4" | 3/8" | 31/32" | 31/32" | 180 |
| 1 1/4" | 1/4" | 3/8" | 1-5/32" | 1 1/8" | 180 |
| 1 1/2" | 1/4" | 3/8" | 1-9/32" | 1 1/4" | 180 |
| 2" | 1/4" | 3/8" | 1-17/32" | 1-15/32" | 180 |
| 2 1/2" | 1/4" | 1/2" | 1-15/16" | 1 7/8" | 300 |
| 3" | 1/4" | 1/2" | 2-17/64 | 2-5/32" | 300 |
| 4" | 1/4" | 1/2" | 2 3/4" | 2 5/8" | 300 |

| PROJECT | APPROVAL STAMP | |
|-----------------|---------------------|--|
| PROJECT: | □ APPROVED | |
| ADDRESS: | ☐ APPROVED AS NOTED | |
| ENGINEER: | □ NOT APPROVED | |
| SUBMITTAL DATA: | REMARKS: | |
| NOTES 1: | | |
| NOTES 2: | | |

Revision: 1/2019