

LANSDALE

VALVE & MANUFACTURING


1040 Broadway Westville, NJ 08093 / Phone: (800)908-0523 / Fax: (856)456-9223 / www.gemfiresprinkler.com

NRS RESILIENT SEATED GATE VALVES

with FLANGED ENDS

General Specifications:

- Valves comply with AWWA C515-15 Standard
- Non-Rising Stem, Resilient Seated (EDPM encapsulated wedge)
- Triple O-Ring Seal
- Available with Optional Test Plug on valve body (special order)
- Post Indicator Valves provided with universal "Indicator Post Plate"
- Mechanical Joint Ends to AWWA C153 /A21.53 Standard
- Flanged Ends to ANSI B16.1, Class 125
- UL Listed/FM Approved at 300 psi water working pressure rating
- NSF-61 and NSF-372 Certified as Lead-Free for use in drinking water systems
- Temperature Range: 42° - 180° F.
- Fusion Bonded Epoxy Coated Interior and Exterior to AWWA C550 Standard
- Flanged Valves available with Hand Wheel or Operating Nut



DIMENSIONS (Inch)							
Size	3"	4"	5"	6"	8"	10"	12"
L	8"	9"	10"	10 1/2"	11 1/2"	13"	14"
H	11 5/8"	13 3/4"	6 1/8"	17 15/16"	21 7/16"	25 3/8"	28 3/4"
D		12"	12"	12"	12"	12"	12"
WT. (lbs.)	41	64	79	103	161	235	339

Part Name	Material	ASTM. Spec.
Body	Ductile Iron	A536 65-45-12
Wedge	Ductile Iron	EPDM Encapsulated
Wedge Nut	Bronze	B62 C83600
Stem	Stainless Steel	AISI 304
Bonnet	Ductile Iron	A536 65-45-12
Gasket	Rubber	EPDM
Gland	Ductile Iron	A536 65-45-12
Thrust Collar	Bronze	B62 C83600
O-Ring	Rubber	EPDM
Post Flange	Ductile Iron	A536 65-45-12
Operating Nut	Ductile Iron	A536 65-45-12
NPT Plug	Bronze	Commercial
Post Flange	Bolt	Stainless Steel AISI 316
Bonnet Bolt	Stainless Steel	AISI 304

PROJECT		APPROVAL STAMP	
PROJECT:		<input type="checkbox"/> APPROVED	
ADDRESS:		<input type="checkbox"/> APPROVED AS NOTED	
ENGINEER:		<input type="checkbox"/> NOT APPROVED	
SUBMITTAL DATA:		REMARKS:	
NOTES 1:			
NOTES 2:			

Revision: 1/2019