

LANSDALE

VALVE & MANUFACTURING

www.breccocorp.com



Riser Clamps

FIG. 261: LOADS (LBS) • WEIGHT (LBS) • DIMENSIONS (IN) • TORQUE (FT-LBS)

Pipe Size	Max Load	Weight	L	G Width	B	C	Bolt Diameter	Torque Values
$\frac{3}{4}$	220	1.1	$8\frac{7}{8}$	1	$2\frac{7}{8}$	$\frac{3}{8}$	$\frac{3}{8}$	21
1		1.1			$3\frac{1}{8}$			
$1\frac{1}{4}$		250			1.6			
$1\frac{1}{2}$	1.6		$3\frac{3}{8}$					
2	1.7		$4\frac{1}{4}$					
$2\frac{1}{2}$	400	1.9	$11\frac{1}{4}$		$\frac{1}{2}$	$\frac{7}{16}$	32	
3	500	1.9	$11\frac{1}{8}$					
$3\frac{1}{2}$	600	2.3	$12\frac{7}{8}$					$5\frac{1}{2}$
4	750	2.4			$6\frac{1}{2}$			
5	1,500	3.6		7				
6	1,600	4.0	$13\frac{1}{4}$	$\frac{1}{2}$	$\frac{1}{2}$	46		
8	2,500	7.6	$14\frac{1}{4}$					
			$18\frac{1}{2}$				8	
				$1\frac{1}{2}$	9			
					12	$\frac{5}{8}$	$\frac{5}{8}$	100

- **Material:** Steel
- **Standard Finish:** Plain or Galvanized
- **Service:** Designed for supporting and stabilizing vertical pipe runs.
- **Clamp is fitted for steel pipe and preferably installed below a coupling or shear lugs.**
- **Ordering:** Specify model number and finish.
- **Complies with Federal Specification WW-H-171E Type 8.**
- **UL Listed**

*Manufactured By Kentsharp for Lansdale International

PROJECT INFORMATION		APPROVAL STAMP	
Project:		<input type="checkbox"/> Approved	
Address:		<input type="checkbox"/> Approved as noted	
Contractor:		<input type="checkbox"/> Not approved	
Engineer:		Remarks:	
Submittal Data:			
Notes 1:			
Notes 2:			