

LANSDALE

VALVE & MANUFACTURING

1040 Broadway Westville, NJ 08093 / Phone: (800) 908-0523 / Fax: (856) 456-9223 / www.gemfiresprinkler.com

IDENTIFICATION SIGNS

For Sprinkler Systems and Devices NFPA 13 Signing Requirements

Material & Finish: Aluminum with mylar facing

	Weight x Height		Thickness
	Inches	mm	Inches
Type 1	9 x 7	229 x 178	
Type 2	6 x 2	152 x 51	.18
Type 3 Rectangular	9 x 7	229 x 178	
Type 3 Round	7-1/4 Diameter	184 Diameter	
Type 4	5 x 7	127 x 178	.14

**THIS VALVE CONTROLS
AUTOMATIC SPRINKLERS**

SUPPLY TO

OPEN

MUST BE AT ALL TIMES

TO BE HANDLED ONLY BY AUTHORIZED PERSON OR
BY EMPLOYEE CARING FOR SPRINKLER SYSTEM

IN CASE OF FIRE
DO NOT SHUT VALVE UNTIL FIRE IS ENTIRELY OUT

WHEN VALVE IS SHUT FOR EMERGENCY - REPAIRS - OR FIRE -
NOTIFY:

REQUEST DIRECTIONS -- RESTORE PROTECTION QUICKLY

TYPE 1

AUXILIARY DRAIN

TYPE 2
AVAILABLE TEXT OPTIONS:

AIR CONTROL	DRAIN
AIR LINE	DRAIN VALVE
ALARM TEST	INSPECTORS TEST
ANTIFREEZE SYSTEM	MAIN CONTROL
AUXILIARY DRAIN	MAIN DRAIN
CONTROL VALVE	

**SPRINKLER
FIRE - ALARM**

WHEN BELL RINGS
CALL
FIRE DEP'T OR POLICE

TYPE 3
RECTANGULAR OR ROUND

HYDRAULIC-SYSTEM

This Building is Protected by a
Hydraulically Designed Automatic
Sprinkler System

Location

No. of Sprinklers

Basis of Design

1. DENSITY GPM/SQ.FT.

2. DESIGNED AREA OF DISCHARGE SQ.FT.

System Demand

1. WATER FLOW RATE GPM

2. RESIDUAL PRESSURE AT THE
BASE OF THE RISER PSI

TYPE 4

PROJECT	APPROVAL STAMP
PROJECT:	☐ APPROVED
ADDRESS:	☐ APPROVED AS NOTED
ENGINEER:	☐ NOT APPROVED
SUBMITTAL DATA:	REMARKS:
NOTES 1:	
NOTES 2:	